



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 14 11 90272 002

**Certificate Holder:** Aplus Pacific Pte Ltd  
11 Greenwood Lane  
The Greenwood  
Singapore 287001  
SINGAPORE

**Product:** Materials For Wall/Ceiling Construction

**Brand Name:** INDOGYPS

**Model(s):** Standard

**Product Details:** Density: 670kg/m<sup>3</sup> ~ 700kg/m<sup>3</sup>  
Tested without paper finish  
(Rating: Non-Combustible)

**Standard(s):** BS 476-4:1970

**Country of Origin:** Indonesia

**Test Report(s):** 7191095804-MEC14/A-MHA, 7191095804-MEC14/B-MHA

**Issued on:** 2014-11-05

**Valid until:** 2017-11-04

Vice-President (Certification Department)  
TÜV SÜD PSB

Page 1 of 1

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)

